



Katie M. Brown
Counsel

Duke Energy
40 W. Broad Street
DSC 556
Greenville, SC 29601

O: 864-370-5296
F: 864-370-5027

Katie.Brown2@duke-energy.com

July 30, 2021

VIA ELECTRONIC FILING

The Honorable Jocelyn G. Boyd
Chief Clerk/Executive Director
Public Service Commission of South Carolina
101 Executive Center Drive, Suite 100
Columbia, SC 29210

**Re: Application Regarding the Acquisition of Progress Energy, Incorporated by
Duke Energy Corporation and Merger of Progress Energy Carolinas,
Incorporated and Duke Energy Carolinas, LLC
SAIDI and SAIFI Reliability Indices
Docket Number: 2011-158-E**

Dear Ms. Boyd:

Pursuant to Regulatory Condition 11.3, on a quarterly basis Duke Energy Carolinas, LLC (“DEC”) and Duke Energy Progress, LLC (“DEP”) must provide to the Commission and to the Office of the Regulatory Staff the System Average Interruption Duration Index (“SAIDI”) and the System Average Interruption Frequency Index (“SAIFI”).


The tables below give the SAIFI and SAIDI results for DEC and DEP on a 12-month roll, with and without Major Event Day(s) (“MEDs”). The IEEE Standard 1366-2003 “Guide for Electric Power Distribution Reliability Indices” method is used for calculating these indices.

Jurisdiction	Date Range	Without MEDs		With MEDs	
		SAIFI	SAIDI	SAIFI	SAIDI
South Carolina Duke Energy Carolinas	12 Months Ending 6/30/21	1.11	163	1.40	563
South Carolina Duke Energy Progress	12 Months Ending 6/30/21	1.63	173	1.69	181

The Honorable Jocelyn G. Boyd
July 30, 2021
Page 2

Jurisdiction	Date Range	Without MEDs		With MEDs	
		SAIFI	SAIDI	SAIFI	SAIDI
South Carolina Duke Energy Carolinas	YTD 6/30/21	0.50	71	0.50	71
South Carolina Duke Energy Progress	YTD 6/30/21	0.88	101	0.88	101

Sincerely,



Katie M. Brown

cc: Ms. Nanette Edwards, Office of Regulatory Staff
Ms. Dawn Hipp, Office of Regulatory Staff
Mr. Michael Seaman-Huynh, Office of Regulatory Staff